

B. E. S. & T. UNDERTAKING

Annexure -I

**Standards of Performance Level by the Distribution Licensee
Format for Quarterly Return to be submitted to the Commission by the Distribution Licensee**

April to June: Q-1 of FY 2020-21

Sr.No.	SOP Regulation No.	Parameters	Stipulated Standards of Performance	Pending Cases / Complaint Nos. (previous Quarter)	Cases / Complaints in current Qtr.	TotalCases/ Complaints	No. of Cases/complaints addressed			Pending Cases / Complaints at end of Qtr.
							Within Standards of performance	More than stipulated time	Total Cases/ Complaints redressed	
	a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
1	4.3	New Connection - Inspection of premises	Seven (7) days for Class I Cities/Urban Areas and Ten (10) days for Rural Areas	133	354	487	320	41	361	126
2	4.4	Intimation of charges where supply from existing lines	Fifteen (15) days for Class I Cities/Urban Areas and Twenty (20) days for Rural Areas	1328	382	1710	650	32	682	1028
3	4.5 & 4.6	Intimation of charges where supply to dedicated or after extension/augmentation.	Thirty (30) days	116	36	152	35	1	36	116
4	4.7	New connection /add. Load where supply from existing line.	One (1) month	17	174	191	175	5	180	11
5	4.8	New connection/add. Load where supply after extension augmenntation	Three (3) months	0	5	5	3	0	3	2
6	4.9	New connection / add. Load where supply after commissioning of sub-station	One (1) year	0	0	0	0	0	0	0
7	4.12	Shifting of Meter/Service Line	Seven (7) days for Class I Cities/Urban Areas and Fifteen (15) days for Rural Areas after receipt of necessary clearances and charges	49	2	51	2	0	2	49
8	6.10	Reconnection of supply after payment of dues	Eight (8) hours for Class I cities, Twenty Four (24) hours for Urban areas and Two (2) days for Rural areas	3	9	12	9	2	11	1
9	4.13	Change of Name	Second billing cycle	9	86	95	39	2	41	54
10	4.13	Change of Category	Second billing cycle	11	96	107	91	0	91	16
11	5.4(a)	Complaint of Voltage Variation -Local Fault	within 2 days	0	0	0	0	0	0	0
12	5.4(b)	Complaint of Voltage Variation -Net work	within 10 days	0	0	0	0	0	0	0

**Standards of Performance Level by the Distribution Licensee
Format for Quarterly Return to be submitted to the Commission by the Distribution Licensee**

April to June :Q-1 of FY 2020-21

Sr.No.	SOP Regulation No.	Parameters	Stipulated Standards of Performance	Pending Cases / Complaint Nos. (previous Quarter)	Cases / Complaints in current Qtr.	TotalCases/ Complaints	No. of Cases/complaints addressed			Pending Cases / Complaints at end of Qtr.
							Within Standards of performance	More than stipulated time	Total Cases/ Complaints redressed	
	a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
13	5.4(c)	Complaints of Voltage Variation - Expansion/augmentation required	within 120 days	0	0	0	0	0	0	0
14	6.1	Fuse off call	Three (3) hours for Class I cities, Four (4) hours for Urban areas and Eighteen (18) hours for Rural areas	0	9575	9575	9534	41	9575	0
15	6.2	Break down of Over head Line	Four (4) hours for Class I cities, Six (6) hours for Urban areas and Twenty Four (24) hours for Rural areas	0	0	0	0	0	0	0
16	6.3	Underground Cable fault	Eight (8) hours for Class I cities, Eighteen (18) hours for Urban areas and Forty Eight (48) hours for Rural areas	0	1107	1107	1085	22	1107	0
17	6.4	Transformer failure	Eighteen (18) hours for Class I cities, Twenty Four (24) hours for Urban areas and Forty Eight (48) hours for Rural areas	0	1	1	1	0	1	0
18	7.2	Meter Reading	Once in every two months	0	124207	124207	124207	0	124207	0
19	7.3	Replacement of Faulty Meter	Within subsequent billing cycle	3862	2023	5885	1129	0	1129	4756
20	7.4	Replacement of Burnt Meter	Eighteen (18) hours for Class I cities, Twenty Four (24) hours for Urban areas and Forty Eight (48) hours for Rural areas	0	301	301	301	0	301	0
21	7.6,7.7	Billing Complaint	During subsequent billing cycle	2315	2176	4491	1830	0	1830	2661

Carried forward cases are inclusive of cases received in latter period of quarter and pending within the stipulated compliance period

B. E. S. & T. UNDERTAKING

Annexure -II

Report of individual complaints where Compensation has been paid
Format for quarterly return to be submitted to the Commission by the Distribution Licensee

April to June Q I of FY2020-21

Sr.No.	Complaint No.	Date of filing complaint	Consumer No.	Name and address of Consumer	Nature of Complaint	Reference Standard of Performance	Amount of Compensation (Rs)	Date of payment of Compensation (DD/MM/YYYY)
1	2	3	4	5	6	7	8	9
2	nil							
3								
4								
5								
6								
7								

NOTE -The report shall be prepared as per category of item for which the compensation is paid for non-observance of Standards of Performance

B. E. S. & T. UNDERTAKING

Annexure - III

Report of action on Faulty Meters (1 Phase /3 Phase)

Format for quarterly return to be submitted to the Commission by the Distribution Licensee

April to June Q-1 of FY 2020-21

Sr.No.	Name of Distribution Licensee	Reference to Overall Standards	Faulty Meters at start of the Quarter (Nos)	Fault Meters added during Quarters (Nos)	Total Faulty Meters (Nos)	Meters rectified/replaced (Nos.)	Faulty Meters pending at end of Quarter (Nos.)
1	2	3	4	5	6	7	8
1	BEST Undertaking	SoP clause 7.3	3862	2023	5885	1129	4756